



**LEE'S SUMMIT**  
MISSOURI



---

## FIRE DEPARTMENT

**Prevention Division  
(816)969-1300**

### **PLAN REVIEW CONDITIONS**

October 18, 2022

SOCIAL PROPERTIES LLC  
807 SW OLDHAM PKWY, LEES SUMMIT MO 64081  
LEES SUMMIT, MO 64081

Permit No: PRCOM20225103  
Project Title: ELSEWHERE APOTHECARY & BOOKSTORE  
Project Address: 809 SW OLDHAM PKWY, LEES SUMMIT, MO 64081  
Parcel Number: 61420052100000000  
Location: MANG ADDITION LOT 6A, A REPLAT OF LOTS 6, 7, 19 & 20 MANG AD DITION---LOT 6A  
Type of Work: CHANGE OF TENANT  
Occupancy Group: MERCANTILE  
Description: RETAIL STORE FOR SALE OF BOOKS AND OTHER ITEMS  
\*Invite Planner to final to verify screening of equipment

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

#### **Fire Plan Review**

**Reviewed By: Jim Eden**

**Approved with Conditions**

1. The exterior door locks shall be openable from the inside without a key, tool, or special knowledge. Provide thumbblatches if needed. Verified at inspection.

#### **Building Plan Review**

**Reviewed By: Joe Frogge**

**Rejected**

1. 2018 IBC 1011.11 Handrails. Flights of stairways shall have handrails on each side and shall comply with Section 1014. Where glass is used to provide the handrail, the handrail shall also comply with Section 2407. (see code for exceptions)

Action required: Provide handrail on both sides of stairs.

2. ICC A117.1 Section 904.3 Sales and service counters and windows. Sales and service counters and windows shall comply with Section 904.3.1 and either 904.3.2 or 904.3.3. Where counters are provided, the accessible portion of the countertop shall extend the same depth as the public portion of the sales and service countertop provided for standing customers. (see code for exception) 904.3.1 Vertical barriers. At service windows or service counters, any vertical barrier between service personnel and customers shall be at a height of 43 inches maximum above the floor. (see code for exception regarding security glazing) 904.3.2 Parallel Approach. A portion of the public use side of the counter surface 36 inches minimum in length and 26 inches minimum and 36 inches maximum in height above the floor shall be provided. A clear floor space positioned for a parallel approach adjacent to the accessible counter shall be provided. The space between the accessible counter surface and any projecting objects above the accessible counter shall be 12 inches minimum. (see code for exception) 904.3.3 Forward Approach. A portion of the public use side of the counter surface 30 inches minimum in length and 36 inches maximum in height above the floor shall be provided. A clear floor space positioned for a forward approach to the accessible counter shall be provided. Knee and toe clearance complying with Section 306 shall be provided under the accessible counter. The space between the accessible counter surface and any projecting objects above the accessible counter shall be 12" minimum.

Action required: Modify plans to comply. At least 36" length of checkout counter to be maximum 36" tall.

3. 2018 IBC 2902.3 Employee and public toilet facilities. For structures and tenant spaces intended for public utilization, customers, patrons and visitors shall be provided with public toilet facilities. Employees associated with structures and tenant spaces shall be provided with toilet facilities. The number of plumbing fixtures located within the required toilet facilities shall be provided in accordance with Section 2902 for all users. Employee toilet facilities shall be either separate or combined employee and public toilet facilities.

Exception: Public toilet facilities shall not be required for:

1. Parking garages where operated without parking attendants.
2. Structures and tenant spaces intended for quick transactions, including takeout, pickup and drop-off, having a public access area less than or equal to 300 square feet.

Action required: Remove note stating "no public restrooms."

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.***