

Temporary Certificate of Occupancy

Permit #: PRRES20211543
Address: 1905 NE PARK RIDGE DR, LEES SUMMIT, MO 64064
Inspected On: Wednesday, October 19, 2022
Inspected By: Khanh Nguyen
Expiration Date: 11/18/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
-------------	------------	----------	-------

Occupancy Inspection - Codes Residential	Khanh Nguyen	Pending	
---	--------------	---------	--

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -Obtain lawn irrigation permit and submit backflow valve test report to city |
| | | -Water meter and sewer manhole are buried |
| | | -Install tamper-proof caps at AC valves |
| | | -Provide address on contrasting background |
| | | -Provide sewer tracer wire port at grade |
| | | -Provide min 2" clearance from patio fireplace siding to concrete |

floor