

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221597
Address: 1499 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Failed	Wednesday, October 19, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Submit engineered approval for field revisions on front canopy framing and post/ beam connections **above ceiling ok to cover pending engineered letter
---	--------------------------	---

Comments: