

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215222
Address: 2039 SW FARM FIELD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, October 19, 2022

Corrective Action Required:

1 Misc

- sod
- gutters
- splash blocks and sump pump discharge to extend 36" from foundation
- address pending driveway inspection
- obtain lawn irrigation permit
- lock out for water heater breaker
- secure a/c whip up off of ground

Back-flow device in basement

Comments: