

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214938  
Address: 1519 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Wednesday, October 19, 2022

Corrective Action Required:

1	Misc	-PROVIDE SPLASH BLOCKS ALL DOWNSPOUT AND SUMP PUMP DISCHARGE LOCATIONS, MIN 36" DISCHARGE FROM FOUNDATION -REMOVE ALL CONSTRUCTION DEBRIS AND TRASH AT REAR OF LOT
---	------	---

**Comments:**