

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222875
Address: 365 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, October 19, 2022

Corrective Action Required:

1	Miscellaneous Correction	Address 6x6 deck post not continuous per plan { not installed to engineers letter on 10/18/22)
---	--------------------------	--

10/19/22 - ENGINEER LETTER STATES FOR 24" CS-16 STRAP CENTERED AT SPLICE FOR NON CONTINUOUS POST REPAIR

Comments: