

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216307
Address: 3120 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, October 20, 2022

Corrective Action Required:

1	Misc	-provide as graded plot plan -locate and identify sewer tracer wire -garage door to be self closing and latching -hardware at rear slider -deck stairs greater than 3/8" difference in rise -multiple stairs to basement greater than 7 3/4" rise -label all non GFCI outlets in unfinished spaces
---	------	--

Comments: