## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20220584

Address: 3212 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Mitchell Schwarz Failed Thursday, October 20,

Residential 2022

## Corrective Action Required:

1 Misc

- -nail top plate to header to design at garage portal frame
- -anchor bolts to be in the middle 1/3 of sill plate see throughout
- -fireblock S basement wall into furr down seal gaps
- -seal floor penetrations for unused hvac places
- -Seal furr down
- -support bath vent in ceiling space above bed 3
- -fire block S bed 3 wall into furr down
- -address fastening of exterior sheathing plans call for nails you have staples

**Comments:**