

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220898

Address: 1013 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811015 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811017 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811019 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811011 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Thursday, October 20, 2022

Corrective Action Required:

2	Miscellaneous Correction	1011 Provide vertical fire blocking every 10' garage Nail exterior wall sheathing near front door Provide anchor bolt front door Solid block nail sheathing powder room Boca plate vents laundry 1013 Seal vertical fire blocking garage Nail burn clips garage Provide electrical protection plate top plate living room Nail hanger above window south bed Tighten anchor bolts hold down north bed Seal fire blocking behind predict north bed closet Provide vertical fire block every 10' hall bath & master closet Nail exterior corners every 12" 1015 Repair core board garage
---	--------------------------	--

Nail burn clips garage
Provide vertical fire block 10' throughput
Seal vertical fire block
Seal vents bedroom closet
Fire block behind pre rock closet
Provide electrical protection plate south bed
Address over bored stud master bath at vanity

1017

Seal vertical fire block kitchen at range
Tighten screw above SGD
Seal upward penetrations hall tub
Fire block behind pre-rock loser
Provide vertical fire block every 10' master closet

1019

Address over bored stud master vanity
Provide fire blocking behind pre-rock south bed closet
Tighten bolt in hold down north bedroom

Comments: