

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216461
Address: 3132 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection	Ryan Heckman	Passed	Thursday, October 20, 2022

Informational:

1 Misc

On 6.3.2022 Friday I performed an inspection of sanitary sewer connection from the pool house.

10-20-22 RH. Sanitary was connected to stub coming out of main to the stub coming from the pool house. Tracer wire was placed along the pipe. Sanitary had blowout between the main and the pool house. Correct bedding was used under and over the pipe.

Comments: