

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215871
Address: 2034 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, October 21, 2022

Corrective Action Required:

1	Misc	-obtain lawn irrigation permit -final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -check water meter at time of final grade and sod -address to be properly illuminated -hardware at rear sliders -fire blocking for engineered I joist in unfinished spaces -security screws at rear basement door
---	------	---

Comments: