

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216303  
Address: 2029 SW RED BARN LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Friday, October 21, 2022

Corrective Action Required:

1 Misc

-address ceiling joists in owners bedroom not supported properly provided hangers for joists for furr down span over 4'  
-fireblock bed 5 walls to ceiling space see dead space at bed 4,5 and bath

OKAY TO INSULATE

**Comments:**