

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215139
Address: 3723 SW MARYVILLE PL, LEES SUMMIT, MO 640823725 SW MARYVILLE PL, LEES SUMMIT, MO
640823727 SW MARYVILLE PL, LEES SUMMIT, MO 640823721 SW MARYVILLE PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Friday, October 21, 2022

Corrective Action Required:

1	Misc	3721 sw maryville pl - Garage entry door needs to latch - Seal exterior penetrations , gas meter and sump discharge
		3723 sw maryville pl - post address - Garage entry door needs to latch - Complete nosing on stairs to living room - Route drain line for humidifier

Comments: