

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213548
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Monday, October 24, 2022

Corrective Action Required:

1	THIRD FLOOR	AREA "A" UNITS AND CORRIDOR APPROVED
---	-------------	---

	AREA "B" UNITS AND CORRIDOR APPROVED
--	---

Corrective Action Required:

2	SECOND FLOOR	AREA A UNITS AND CORRIDOR APPROVED
---	--------------	---------------------------------------

	AREA B UNITS AND CORRIDOR APPROVED
--	---------------------------------------

Corrective Action Required:

3	FIRST FLOOR	AREA A UNITS AND CORRIDOR APPROVED ECEPT AS NOTED: 129-INCOMPLETE
---	-------------	---

	AREA B -COMMON AREAS INCOMPLETE -Address fire wall damage and penetrations both sides -Seal dead spaces
--	---

Corrective Action Required:

4	ELEVATOR 1	
---	------------	--

Corrective Action Required:

5 STAIR TOWER 1 -PROVIDE VERTICAL FIREBLOCKING MAX 10' OC AT SHARED WALL

Corrective Action Required:

6 STAIR TOWER 2 -PROVIDE VERTICAL FIREBLOCKING MAX 10' OC AT SHARED WALL

Corrective Action Required:

7 STAIR TOWER 3

Corrective Action Required:

8 STAIR TOWER 4

Comments: