CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20210263Address:1801 NW OBRIEN RD, LEES SUMMIT, MO 64081520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:	
Miscellaneous Inspection		Robb Popp	Partial	Monday, October 24, 2022	
Corrective	e Action Required:				
1	Miscellaneous	Parking lot located at 1801 NW Obrien Rd - Parking lot a is allowed to be utilized for its intended purpose. Outstanding items noted on the Occupancy inspections completed on 9/21/2021 shall be completed prior to full release.			
	Correction				
Corrective	e Action Required:				
2	Misc	10/24/22 PRE FINAL WALK	1/22 PRE FINAL WALK OF UNITS ONLY ON 2A:		
		-PROVIDE PERMANENT SIGNAGE THROUGHOUT			
		-PROVIDE SPARK RINGS AT ANY AND ALL RECEPTACLES SET BACK MORE THAN 1/4" TO NON COMBUSTIBLE FINISHES, AND EXTENDED TO FACE OF FINISH AT ALL COMBUSTIBLE FINISHES THROUGHOUT			
		ADDRESS THRESHOLD HEIGHTS GREATER THAN 1/2" AT EXTERIOR DOORS			
		-ACTIVATE AND UNCOVER	ALL SMOKE/ COMBO DETEC	TORS FOR INSPECTION	
		-PROVIDE LOCKOUTS AT A	LL HARDWIRED APPLIANCES	THROUGHOUT	
		2021-Missing cover plates	021-Missing cover plates		
		2022-Provide shower, rest compliant with 2017 A117.	room grab bars, and electri 1	cal panel height	
		•	ischarge line above bowl of	sink, blank off	
			el disconnects, secure mc,	missing sprinkler	

escutcheon, cover plates

2024, 2025-ok except for throughout conditions

2027-Seal penetrations at mechanical and secure whip

2029- Provide hammer arrestor at kitchen, secure dishwasher discharge,

provide gfci protection at laundry, blanks at panel, seal penetrations in mechanical

Comments: