

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20221526  
Address: 904 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Michael Harkins	Partial	Tuesday, October 25, 2022

Corrective Action Required:	
1 THE FOLLOWING AREAS ARE APPROVED	2 HOUR WALL TYPE P1 UL U301 1ST LAYER 5/8 TYPE X NORTH SIDE OK FOR 2ND LAYER

**Comments:**