

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213072
Address: 1225 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Tuesday, October 25, 2022

Corrective Action Required:

1	Misc	-Provide venting for water heater **Provide installation document for water heater. Check venting requirement
		-Provide combustion air openings per code **min 100 sq inches for each CA opening
		**OK TO ROCK

Comments: