

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224612
Address: 2931 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, October 25, 2022

Corrective Action Required:

1	Misc	-seal all penetrations and gaps in vertical to horizontal fireblocking -ensure vertical to horizontal fire blocking every 10' (see exercise room S wall, E wall in basement) -fireblock s family room wall into furr downs -install fireplace or land electric To box -midway strap dwv in bath
---	------	--

Comments: