

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222729
Address: 6 SW 2ND ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	John Jackson	Passed	Tuesday, October 25, 2022

Informational:	
1	Misc
	09/20/22 Tuesday JMJ
	Visual inspected copper that was pulled to the inside of building suite 103.
	No connection made inside or outside.
Informational:	
2	Misc
	10/25/22 Tuesday JMJ
	Visual inspected connection of 1" water line on the outside of building suite 103.

Comments: