

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220646
Address: 805 NE LAKEWOOD BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	Khanh Nguyen	Not Ready	Wednesday, October 26, 2022

Corrective Action Required:

1	Misc	-Installed gas piping is not per plan. There seems to be additional rooftop unit beside the RTU-1. Gas piping size and layout shall be per plan or resubmit new plan
		**9/1/22-This is a 3rd gas service inspection. Reinspection fee is assessed
		**10/26/22-Reinspection fee assessed. Revised plan not submitted to city and available on site. Do not schedule an inspection until the revised plan is approved

Comments: