

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215487
Address: 2002 SW 26TH TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	Ryan Heckman	Passed	Thursday, October 27, 2022

Informational:

1 Misc

On 4.12.2022 Tuesday Temp Stop installed 100 ft of 2-inch flexible plastic water service line. Proper bedding was utilized.

8-22-22 RH. Backflow and water meter was installed and filled around.

Comments: