

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215286

Address: 3643 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643643 NE AKIN DR, Unit:C, LEES SUMMIT, MO 640643643 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Failed	Thursday, October 27, 2022

Corrective Action Required:

1 Misc

UNIT A:

-Strap master shower wall top plates lapped less than two ft

UNIT B:

UNIT C:

-Move the gas line away from attic access

-At rear bedroom closet, strap wall top plate notched more than 50% and Fb as required

-Protect water lines with BOCA plate at bottom wall plate

**OK TO INSULATE

Comments: