

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20220363  
Address: 3990 SW FLINTROCK DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Stabilized Subgrade</b>	Ryan Heckman	Passed	Thursday, October 27, 2022

Informational:

1 Misc

On 6.23.2022 Spalding applied chemical stabilization to the pavement throughout the site.

ON 6.23.2022 Spalding conducted a proof roll using a 20 ton tandem truck and pass the proof roll.

**Comments:**