

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214607

Address: 902 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081904 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081906 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081908 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081910 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081900 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Michael Harkins	Failed	Thursday, October 27, 2022

Corrective Action Required:

1	Miscellaneous Correction	TABLE SERVICE PANELS / MAIN DISCONNECT INSTALL DISCONNECT LAND GROUNDING ELECTRODE (UFER)
---	--------------------------	---

Comments: