## CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 FAX (816) 969-1201 (816) 969-1200

## **Temporary Certificate of Occupancy**

Permit #: PRRES20213189

Address: 1912 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

**Inspected On:** Monday, October 31, 2022

**Inspected By:** Khanh Nguyen

**Expiration Date:** 11/30/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

**Occupancy Inspection -Codes Residential** 

Khanh Nguyen

Pending

Corrective Action Required:

Misc Complete lawn irrigation permit application and submit backflow

valve test report to city

-Fix sunken grading at front

-Install tamper-proof caps at AC valves

-Rear exterior stair not compliant. Stair riser height shall have maximum difference of no more than 3/8". (FYI:Top riser height is measured from top of door threshold to tread); provide handrail for

both stairs

\*\*The top stair tread must be below the door threshold with riser

height consistent with other stair risers.

-Provide sewer tracer wire port at grade

\*\*Remove the tree planted adjacent to the water meter pit