

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221526
Address: 904 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Partial	Tuesday, November 01, 2022

Corrective Action Required:	
1 THE FOLLOWING AREAS ARE APPROVED	2 HOUR WALL TYPE P1 UL U301 1ST LAYER 5/8 TYPE X NORTH SIDE OK 2ND LAYER 5/8 type X NORTH SIDE OK TO TAPE

: NOTE FIRE CAULK ALL PENETRATIONS & ROOF DECK :

Comments: