

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213548  
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Partial	Tuesday, November 01, 2022

Corrective Action Required:

1	THIRD FLOOR	AREA "A" UNITS AND CORRIDOR APPROVED
		AREA "B" UNITS AND CORRIDOR APPROVED
		AREA "C" UNITS AND CORRIDOR APPROVED

Corrective Action Required:

2	SECOND FLOOR	AREA A UNITS AND CORRIDOR APPROVED
		AREA B UNITS AND CORRIDOR APPROVED
		AREA C UNITS AND CORRIDOR APPROVED

Corrective Action Required:

3	FIRST FLOOR	AREA A UNITS AND CORRIDOR APPROVED ECEPT AS NOTED:
---	-------------	---

129

- SUPPORT/ SECURE ALL ELECTRICAL PER CODE,
- NAIL HOLD DOWNS IN GUEST BED
- PROVIDE ANCHOR BOLTS AT SGD
- REMOVE BONDING SCREW FROM PANEL
- SEAL TOP PLATES IN MASTER
- SEAL FIREWALL IN JOIST SPACE AT MASTER BATH
- REMOVE 90 DEGREE BENDS FROM OVER SPANNED DRYER DUCT

AREA B

- COMMON AREAS INCOMPLETE

AREA C

- SEAL PENETRATION IN FIREWALL
- 115- ADDRESS HOLE BORED IN TRUSS TOP CHORD
- 112-ELEVATOR LOBBY- ADDRESS TRUSS SPACING

Corrective Action Required:

4 ELEVATOR 1

Corrective Action Required:

5 STAIR TOWER 1

- PROVIDE VERTICAL FIREBLOCKING MAX 10' OC AT SHARED WALL

Corrective Action Required:

6 STAIR TOWER 2

- PROVIDE VERTICAL FIREBLOCKING MAX 10' OC AT SHARED WALL

Corrective Action Required:

7 STAIR TOWER 3

Corrective Action Required:

8 STAIR TOWER 4

**Comments:**