

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213805
Address: 2105 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, November 01, 2022

Corrective Action Required:

1	Misc	-handrail at front stairs must be between 34"-38" -interconnection required of all smoke detectors -install sliding glass door hardware and secondary lock -provide hammer arrestor at dishwasher -repair rock at garage wall and garage ceiling -install ceiling light master bed -provide pressure regulator at main water line -provide anti siphon device at spigot basement, shear off set screw head after tightening -replace vegetation at rear of lot disturbed from construction
---	------	--

Comments: