

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213811
Address: 3813 SW MARYVILLE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, November 01, 2022

Corrective Action Required:

1	Misc	-provide cover plates at garage outlets -fireblock beam pockets at foundation wall garage -provide security screws, door hardware, and weather strip at basement walkout -install exterior light at basement walkout -provide (2) 1/2" through bolts each post/beam connection at deck -handrail height at deck stairs must be between 34"-38" -Sump pump discharge min 36"
---	------	---

Comments: