

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213815
Address: 1905 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, November 01, 2022

Corrective Action Required:

1	Misc	-provide guard or wall with rock at bottom flight basement stairs, (PROVIDE SPINDLES OR CLOSE OFF GUARDRAIL, OPENING CANNOT BE LARGER THAN A 4" SPHERE CAN PASS THROUGH)
---	------	--

Comments: