



8787 RENNER BLVD. SUITE 100  
LENEXA, KS 66219

913 + 498 - 1550  
finklewilliams.com

November 2, 2022

Paragon Star North Village Parking Garage and Site Development

Permit No: PRCOM20220598

October 26, 2022 Plan Review Response

Drawings have been updated to conform with the comments from the plan review per the responses below.

**Building Plan Review Reviewed**      **By: Joe Frogge**

*15. 2018 IPC 502.1 General. Water heaters shall be installed in accordance with the manufacturer's installation instructions. Oil-fired water heaters shall conform to the requirements of this code and the International Mechanical Code. Electric water heaters shall conform to the requirements of this code and provisions of NFPA 70. Gas-fired water heaters shall conform to the requirements of the International Fuel Gas Code.*

*Action required: Provide expansion tank to water heater or provide verification that water heater installed will not require expansion tank in the manufacturer's written instructions.*

**Response:** Detail updated to reflect installed expansion tank