

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214608

Address: 916 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081918 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081920 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081922 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081924 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081926 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081928 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081914 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Michael Harkins	Failed	Wednesday, November 02, 2022

Corrective Action Required:

1	Miscellaneous Correction	OK TO SHEETROCK & TAPE LIVING ROOM PROVIDE ADDRESS
---	--------------------------	---

INSTALL DISCONNECT & CONNECT CONCRETE ENCASED ELECTRODE

Comments: