

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221744
Address: 201 SE M 291 HWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Tuesday, October 25, 2022

Corrective Action Required:

1	Miscellaneous Correction	<ul style="list-style-type: none">-Commercial License Tax Fee must be paid before any occupancy can be issued-Complete all corrections for other departments-Correct threshold height greater than 1/2" at entry door-Provide GFCI protection under public sink-Restroom sign at public restroom to be 48"-60" to braille-Sidewall grab bars to extend min 54" in both restrooms-Label electrical panels-Provide non absorbant finish min 48" high in employee restroom-Set sprinkler escutcheon in employee restroom-Provide GFCI protection at receptacle near-Provide roof access to inspect RTU
---	--------------------------	---

Comments: