

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20203584  
Address: 3126 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Ryan Heckman	Passed	Wednesday, November 02, 2022

Informational:

1 Misc

Sidewalk has been formed and rock is installed but needs to be compacted. The forms appear to be ADA compliant at this time. I also asked the contractor to clean up the dirt and rock that is in the street due to the forming up of the sidewalk.

11-2-22 RH. Sidewalk meets LS and ADA specification.

**Comments:**