

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216389
Address: 3230 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, November 02, 2022

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- Gas piping incomplete at fire place, provide shut off valve and plumb- Secure CSST at fire place- Make accessible for inspection front porch cover- Fire block top plate of double wall (first to second floor) Master and master bathroom- Address over notched hip rafter LVL bedroom 3 exterior wall- Address over notched hip rafters over cripple wall bedroom 2- Flashing and trim window at front of house- Install sliding door |
|---|------|---|

Comments: