

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215650
Address: 2038 SW FARM FIELD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------|--------------|----------|---------------------------------|
| Sidewalk Inspection | Ryan Heckman | Partial | Wednesday, November 02, 2022 |

Informational:
1 Misc 11-2-22 RH. Half of sidewalk was formed up and aggregate was placed and compacted. This side was good to pour. The Sidewalk connecting to ADA Ramp was not formed up and did not have aggregate compacted.

Comments: