

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215763
Address: 3116 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, November 02, 2022

Corrective Action Required:

1	Misc	-pay all fees -splash blocks and sump pump discharge to extend 36" from foundation -stairs at front patio greater than 3/8" difference -rock bottom of furr out in garage -afci protection for dining room -spark rings as required see above fire place and check kitchen outlets
---	------	---

Comments: