

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215296
Address: 1600 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, November 03, 2022

Corrective Action Required:

1	Misc	-final sidewalk inspection required, contact development services to schedule -provide GFCI protection at wall outlet wet bar right of fridge, less than 6' from wet bar sink -downspout and sump pump discharge min 36" distance from foundation -provide angle clip at inner ply of dbl beam at deck -no larger than 7 3/4" rise and no more than 3/8" variance between riser heights at deck stairs -install cover plate at TV receptacle deck, GFCI protection required at outlet
---	------	--

Comments: