

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20222496

Address: 2501 NE COLBERN RD, LEES SUMMIT, MO 640862601 NE COLBERN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Air Test	Adam Nacke	Partial	Thursday, November 03, 2022

Informational:

1 Misc

11-3-22 AN. Hydrostatic test for low pressure sewer main at 80 psi for 2hours
Line 1, 2 and part of 3 up to Blackwell passed

On line 3 we still need to hydrostatic test all the main that is getting bored
off of Blackwell

Comments: