

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20214053  
Address: 2020 SW HOOK RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Punch List Inspection</b>	Ryan Heckman	Partial	Friday, November 04, 2022

Informational:

1 Misc

10-26-22 RH.

1. All areas with a Dot can be grouted.
2. All areas with an X need replaced from joint to joint.
3. All cables on Storm inlets need to be removed and grouted.
4. All storm lids need be lifted and made sure they are grouted on inside.

11-4-22 RH. Redford has started working on punch list items around the subdivision.

**Comments:**