

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20222754  
Address: 2217 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:         | Outcome: | Date:                     |
|---|--------------------|----------|---------------------------|
| <b>All Rough Inspection - Residential</b> | Patrick Schonfeldt | Failed   | Friday, November 04, 2022 |

Corrective Action Required:

|   |                          |  |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | No deck pier inspection on record<br>Covered deck shall have 1 roof vent & 4 soffit vents per plan<br>Seal fire blocking deck fireplace (covered)<br>Provide CS-PF exterior bracing at foyer per plan Provide CS-PF window left of fireplace<br>Provide electrical nail guard at bed 3 vanity<br>Provide flashing above horizontal window trim |
|---|--------------------------|--|

**Comments:**