

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223181
Address: 1401 NW RIVER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Shawn Hoffman	Partial	Friday, November 04, 2022

Informational:

1	Misc	: PRECAST FIELD LIGHT POLE BASES : * PUMP WATER FROM PIERS BEFORE POURING * - 10/7/22 PRECAST POLE BASE # 3 OF 27 BETWEEN FIELDS # 1 & # 2 23' DEEP PIER REBAR PER PLAN TYPE F3 - 10/10/22 # S4 BETWEEN FIELDS 1 & 2 42" DIA, 23' DEPTH, 18 # 7 BARS VERTICAL W/ #4 HORIZONTAL TIES @ 12" - - 10/10/22 S1 FIELD 1 AT BLEACHERS 42" DIA 21' DEPTH 18 # 7 BARS VERTICAL W/ #4 BARS HORIZONTAL TIES, S14 BETWEEN FIELDS 5 & 6 42" DIA 23' DEPTH 18 # 7 BARS W/ # 4 HORIZONTAL BARS @ 12" - : ALSO CALLED IN ON PERMIT # 20201955 : - 10/11/22 S2 FIELD 1 AT BLEACHERS 21' DEPTH S12 WEST SIDE FIELD 5/ PARKING LOT 21' DEPTH S13 BETWEEN FIELDS 5 & 6 23' DEPTH, ALL SAME REBAR CAGE AS ABOVE - - 10/13/22 S5 & S6 BETWEEN FIELDS 2 & 3 23' DEPTH S11 FIELD 5 @ PARKING LOT 21' - - 11/3/22 S15 & S16 BETWEEN FIELDS 6 & 7 23'- - 11/3/22 2ND TRIP S7 & S8 BETWEEN FIELDS 3 & 4 -11/14/22 PRECAST LIGHT POLS BASES P7 + P8
---	------	---

Comments: