

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20221512  
Address: 2601 NE MCBAINE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Friday, November 04, 2022

Corrective Action Required:

1	Misc	-Approval from water and planning departments required -Paint all exterior gas lines -Provide tamper resistant schrader valves at exterior units -Secure AC whips per code -Sinks in restrooms to be max 34" aff to top of rim -Relocate grab bars in restrooms to comply with 2017 ICC A117.1
---	------	---

**Comments:**