

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215028

Address: 2603 NE MCBAINE DR, LEES SUMMIT, MO 640642605 NE MCBAINE DR, LEES SUMMIT, MO
640642607 NE MCBAINE DR, LEES SUMMIT, MO 640642609 NE MCBAINE DR, LEES
SUMMIT, MO 640642611 NE MCBAINE DR, LEES SUMMIT, MO 640642613 NE MCBAINE
DR, LEES SUMMIT, MO 640642615 NE MCBAINE DR, LEES SUMMIT, MO 640642617 NE
MCBAINE DR, LEES SUMMIT, MO 640642601 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Friday, November 04, 2022

Corrective Action Required:

1	Miscellaneous Correction	**2603 -Approval from water and planning departments required -Paint all exterior gas lines -Provide tamper resistant schrader valvles at exterior units -Secure AC whips per code -Relocate grab bars in restrooms to comply with 2017 ICC A117.1
---	--------------------------	---

Comments: