

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20204351
Address: 2529 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082
Inspected On: Friday, November 04, 2022
Inspected By: Mitchell Schwarz
Expiration Date: 12/4/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Pending	

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | -raise water meter well to grade
-water meter to be 14-18" from meter to lid |
|---|------|---|