CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #:	PRRES20204351
Address:	2529 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082
Inspected On:	Friday, November 04, 2022
Inspected By:	Mitchell Schwarz
Expiration Date:	12/4/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Pending	

Corrective Action Required:

1 Misc

-raise water meter well to grade -water meter to be 14-18" from meter to lid