

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223245
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Patrick Schonfeldt	Failed	Friday, November 04, 2022

Corrective Action Required:

1	Miscellaneous Correction	1A047B-OK 1A056-OK 1A046 - OK 9/6/2 02-14056 - OK 10/3/22 10/10/22 Sterile Storage room 02-1A079 OK - 10/20/22 HARD LID 02-1A083 OK -
---	-----------------------------	--

Corrective Action Required:

2	Miscellaneous Correction	- 10/17/22 ROOM 02-1A094 FIRE CAULK PENETRATIONS AT MC CABLES TO RACEWAYS & MC ABOVE DOOR LOW VOLT, FIRE CAULK END OF SLEEVES PENETRATING WALL ABOVE DOOR
---	-----------------------------	---

Corrective Action Required:

3	Misc	11/4/22 - CONTROL RM 02-1A082 FIRE CAULK ALL PENETRATIONS
---	------	---

Comments: