

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213596
Address: 321 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Not Ready	Friday, November 04, 2022

Corrective Action Required:

3	Misc	-pay all fees -Garage stairs greater than 3/8 difference in rise -spark rings at kitchen/ prep kitchen / basement wet bar counter top outlets where required by code -security screws at exterior doors 2 per hinge and strike plate -spark ring at outlet above fire place -missing hardware at front door -remove chandelier in master bath within 8' of tub edge -safety glazing for basement Rear windows closer than 18" to floor
---	------	---

OBTAIN IRRIGATION PERMIT SUBMIT BACKFLOW CERTIFICATION

Comments: