

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215280

Address: 3659 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643659 NE AKIN DR, Unit:C, LEES SUMMIT, MO
640643659 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643659 NE AKIN DR, Unit:A, LEES
SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	Khanh Nguyen	Failed	Monday, November 07, 2022

Corrective Action Required:

1	Misc	-Pressure test less than ten psi unit B
---	------	---

Comments: