

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220584  
Address: 3212 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Ryan Heckman	Partial	Monday, November 07, 2022

Corrective Action Required:

1	Misc	11-7-22 RH. Driveway is formed up and aggregate is placed and compacted. Approved to pour.
---	------	--

**Comments:**